



Product Service


CERTIFICATE

No. Z2 092315 0006 Rev. 03

Holder of Certificate: **SHARP CORPORATION**

282-1 HAJIKAMI
KATSURAGI-SHI NARA
639-2198 JAPAN

Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-crystalline Silicon Photovoltaic (PV) Modules

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 882161910904

Valid until: 2024-11-28

Date, 2021-06-07

(Xinlian LUO)

CERTIFICATE

No. Z2 092315 0006 Rev. 03

Model(s):

1000VDC modules :

NU-325KC, NU-330KC, NU-JC320B
NU-JC330, NU-AC310, NU-AC300B
NU-AF365, NU-AF370

1500VDC modules :

NU-395KG, NU-JB395, NU-AF380C,
NU-AF365E, NU-AF370E, NU-AF345H
NU-JD440, NU-440KG, NU-JC365
NU-JC370, NU-365KC, NU-370KC
NU-365KG, NU-370KG, NU-JC355B
NU-JC360B, NU-JD440M, NU-JD445
NU-JD445M, NU-445KG

Parameters:

Safety Class: Class II

Maximum System Voltage: 1000V DC or 1500V DC

Test method of salt mist test: Test method 6

Construction: Framed, with Junction box, cable and connector.

Fire Safety Class: Class C according to UL790

Tested**according to:**

IEC 61215-1:2016
IEC 61215-1-1:2016
IEC 61215-2:2016
IEC 61730-1:2016
IEC 61730-2:2016
IEC 62716:2013
IEC 61701:2020